

Condensed Cross Reference



Power/Electronic Fuses

POWR-GARD™ Products

This cross reference covers most popular fuses for which there is a similar Littelfuse standard item. Furnished for your convenience, it is meant to serve as a guide only for product selection. We suggest you check all applicable specifications before making substitutions. For special applications, consult the factory.

For more complete information, and for fuse block and medium voltage fuse cross referencing, send for Cross Reference Booklet EC501 or call 1-800-TEC-FUSE (1-800-832-3873).

COMPETITION	LITTELFUSE	COMPETITION	LITTELFUSE	COMPETITION	LITTELFUSE	COMPETITION	LITTELFUSE
10KOTN	NLN	CLL	KLLU or KLPC	JHC	JTD_ID	NCLR	KLNR
10KOTS	NLS	CLU	KLLU or KLPC	JJN	JLLN	NON	NLN
50KOTN	NLN	CM	BLF	JJS	JLLS	NOS	NLS
50KOTS	NLS	CMF	BLN	JKS	JLS	NRN	NLN
A	251	CNM	FLM	KAA	L15S	NRN (15-60A)	NLKP
A013F	L15S	CNQ	FLQ	KAB	L25S	NRS	NLS
A015F	L15S	CRN-R	FLNR_ID (note 4)	KAC	KLC	OT	NLN
A015R	L15S	CRS-R	FLSR_ID	KBH	L50S	OTM	BLF or BLN
A025F	L25S	CSF13X	L15S	KLM	KLKD	OTN	NLN
A050F	L50S	CSF25X	L25S (AC only)	KLMR	CCMR	OTS	NLS
A060F	L60S	CSF50P	L50S	KLU	KLLU or KLPC	REN	RLN
A060UPL	KLK	CSF60C	KLC (AC only)	KN	KLNR	RES	RLS
A070F	L70S	CSF60X	L60S (AC only)	KON	NLN	RF	RLN
A13X	L15S	CSF70P	L70S	KOS	NLS	RFA	L15S
A25X	L25S (AC only)	CTN-R	KLNR	KRPC (SP)	KLPC	RFC	KLC
A2D-R	LLNRK	CTS-R	KLSR	KRPC-L	KLPC	RFL (750V)	L70S (700V)
A2K-R	KLNR	EBS	BLS	KS	KLSR	RFN (Gould)	RLN
A3T	JLLN	ECNR	FLNR_ID (note 4)	KTK	KLK	RFS (Gould)	RLS
A4BQ	KLPC	ECSR	FLSR_ID	KTKR	KLKR	RFV	L50S
A4BT	KLLU or KLPC	ELN	LKN	KTNR	KLNR	RHN	KLNR
A4BY	KLPC or KLLU	ELS	LKS	KTSR	KLSR	RHS	KLSR
A4J	JLS	ERN	RLN	KTU	KLPC	RLN (Gould)	LKN
A50P (type 1 & 4)	L50S	ERS	RLS	L	KLLU or KLPC	RLS (Gould)	LKS
A60X	L60S	FNA	FLA	LOL	KLPC or KLLU	S	SOO
A6D-R	LLSRK	FNB	235	LCU	KLPC or KLLU	SA	SAO
A6K-R	KLSR	FNM	FLM	LENRK	LLNRK	SC	SLC
A6T	JLLS	FNQ	FLQ	LESRK	LLSRK	SCLR	KLSR
A70P	L70S	FNQ-R	KLDR	LKN	LKN	SEC	SLC
ACK	CCK	FRN-R	FLNR_ID (note 4)	LKS	LKS	SF13X	L15S
AG	SLC	FRS-R	FLSR_ID	LKU	KLLU	SF25X	L25S
AGA	301	FWA (note 3)	L15S	LONRK	LLNRK	SF50P	L50S
AGC	312	FWH (note 3)	L50S	LOSrk	LLSRK	SF60X	L60S
AGU (1-30A)	BLN	FWP (note 2)	L70S	LPCC	CCMR	SF70P	L70S
AGW	303 (note 1)	FWX (note 2)	L25S	LPJ (SP)	JTD_ID	SFE	307 (SFE)
AGX (1/500-1/10A)	361	GDA	216	LPNRK (SP)	LLNRK	SL	SLO
AGX (1/8-30A)	362	GDB	217	LPSRK (SP)	LLSRK	T	TOO
AJT	JTD_ID	GOC	218	MCL	KLK	TJN	JLLN
ANL	CNL	GDL	313	MDA	326	TJS	JLLS
ANN	CNN	GEB	LEB	MDL	313	TL	TLO
ATC	ATO (257)	GEBN	LET	MDQ	313	TR	FLNR_ID (note 4)
AT-DE	FLNR_ID (note 4)	GFA	251	MDV	315	TRM	FLM
ATDR	CCMR	GFN	FLA	MDX	313	TRN-R	FLNR_ID (note 4)
ATM	KLK	GGC	312	MEN	FLM	TRS	FLSR_ID
ATMR	KLKR	GGM	235	MEQ	FLQ	TRS-R	FLSR_ID
ATQ	FLQ	GGX (1/500-1/10A)	361	MID	FLA	W	WOO
ATQR	KLDR	GGX (1/8-30A)	362	MOF	BLN	XL25X	L25S
AX	401	GLR	LGR	MOL	BLF	XL50F	L50S (note 2)
AXRAD	252	GMT	401	MTH	312	XL70F	L70S (note 2)
BAF	BLF	HCLR	KLKR				
BAN	BLN	HCTR	KLDR				
BBS	BLS	HEB	LEB				
CGL (2-100A)	FIL	HET	LET				
CGL (125-600A)	FIIC	HLR	LHR				
CJ	JLS	J	JLS				
CJS	JLS	JDL	JTD_ID				
CLF	KLPC or KLLU	JFL	JLS				

1) Use #30707.5 to replace AGW 7.5 Amp
 2) Check specific mounting dimensions before substituting.
 3) Check fuse characteristics and mounting dimensions for specific application before substituting.
 4) For 1/10 - 30 amperes, order non-indicating FLNR series fuses.
 5) For 70-600 amp order non-indicating JTD series fuses.
 Remember a fuse may be used in circuits where the fuse's voltage rating is equal to or greater than the circuit voltage, unless otherwise stated on the fuse. For example, the FLSR_ID indicating fuse has a voltage rating of 75-600 volts. This fuse can be used on 600 volts, 480 volts, 250 volts, 125 volts, or 75 volts. Never use a fuse in a circuit having higher rated voltage than the fuse.